

कार्यालय अग्निशमन अधिकारी, जनपद फतेहगढ़ उ० प्र०

पत्रांक: एक एस / कार्ड- 12022 / 1058

दिनांक:- सितम्बर 19, 2022

सेवा में,

जे० एस० एम० पब्लिक स्कूल

बनखड़िया फतेहगढ़, फर्रुखाबाद

विषय: प्रतिष्ठान / फर्म में स्थापित फायर एक्सटिंग्यूशरों की कार्यशीलता के प्रमाणीकरण के सम्बन्ध में।  
सन्दर्भ: आपके प्रार्थना पत्र संख्या दिनांक 18.09.2022 उपरोक्त संदर्भित विषय आपके प्रार्थना पत्र के क्रम में आपके संस्थान में उपलब्ध 10 अदद फायर एक्सटिंग्यूशरों की टेस्टिंग हेतु शासनादेश संख्या: 1120(1)/आठ, दिनांक 27.12.1982 में दिए गए निर्देशों के अनुसार निर्धारित शुल्क 120.00 रु० भारतीय स्टेट बैंक शाखा फतेहगढ़ जनपद फर्रुखाबाद में घातान संख्या SF30015 दिनांक 19.09.2022 द्वारा जमा कराया गया। प्राप्त रसीद प्राप्त होने के उपरान्त 10 अदद फायर एक्सटिंग्यूशरों का परीक्षण किया गया, जिसका विवरण निम्नवत है।

क्र०सं०	फायर एक्सटिंग्यूशरों का प्रकार	क्षमता	संख्या	कार्यशीलता / अकार्यशीलता
1	एपीपीसी	06 किया0	08 अदद	कार्यशील
2	सीपीपीसी	4.5 किया0	02 अदद	कार्यशील
3	मैकेनिकल फोम	09 ली0	03 अदद	कार्यशील
4	फायर व्हेटस		06 अदद	कार्यशील

इस प्रकार आपके संस्थान में उपलब्ध फायर एक्सटिंग्यूशरों की कार्यशीलता उपरोक्तानुसार पायी गयी। अतः प्रतिष्ठान में स्थापित फायर एक्सटिंग्यूशरों की कार्यशीलता प्रमाणित की जाती है। शेष सुरक्षा व्यवस्था मानकों के अनुसार वांछनीय होगी तथा समय-समय पर इनकी कार्यशीलता प्रमाणित कराये जाने का उत्तरदायित्व प्रबंधक/स्वामी का होगा।



प्रभारी अग्निशमन अधिकारी  
जनपद फतेहगढ़

FIRE SAFETY CERTIFICATE

APPENDIX - XII

No. UPFS/2023/Misc-132 / Prov /FGH

Dated: 23/09/2023

Certified that the .....JSM Public School.....(name of the building or premises) at ..... Bankhadia Fatehgarh District Farrukhabad (address) comprised of .....Zero.....basement(s) and .....two upper floors only ..(ground floor and first floor)..... owned/ occupied by .....JSM Public School..... (name of the Institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on .....19/06/2023.....(date of inspection) in the presence of .....Mrs. Meena Saxena ..... (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes .....XII th..... ( X/ XII) With effect from .....20/06/2023..... for a period of .....03..... year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Building height is less than 7 mtrs.
2. Extinguishers and hydrant work is done in the premises, should be kept in working condition and renewed timely.
3. Water storage capacity of the tank should be increased in the future, if required.
- 4.

Issued on ...23/06/2023... ( date of issue) at.....Fatehgarh.....(place) by

\*Strike out whichever is not applicable.

Signature with Seal: .....प्रभारी फायर सविरी फतेहगढ़

Name : .....Incharge, CFO.....

Designation : .....Incharge, CFO.....

Name & Address of Department/ Office: CFO Fatehgarh

To

JSM Public School  
Bankhadia Fatehgarh  
Dist.Farrukhabad...U.P.

(Name & Address of the Institution)

